

## Pre Bid Clarification No. 2 (TN-294)

(Ref. Letter No.RV/PN/EHV/TN-292 & RV/PN/EHV/TN-294 dated 21.6.10 of M/s. Larson & Toubro limited)

S. No.	Volume / Book No.	Clause	Queries	Clarifications
1.	400 KV GSS Barmer		Please confirm that spare feeders in the existing auxiliary AC, DC & Lighting distribution boards shall be utilized for the proposed bays under extension.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
2.	General		We presume that the existing Battery & Battery Charger capacity is adequate for present scope of work.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
3.	General		Please confirm that existing facilities for earthing, illumination, main cable trench and lightning protection shall be utilized for the proposed bays under extension.	Confirmed, but extension work, wherever, required shall be in scope of Specification.
1.	400 KV GSS at Jaisalmer		Please confirm that spare feeders in the existing auxiliary AC, DC & Lighting distribution boards shall be utilized for the proposed bays under extension.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
2.	General		We presume that the existing Battery & Battery Charger capacity is adequate for present scope of work.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
3.	General		Please confirm that existing facilities for earthing, illumination, main cable trench and lightning protection shall be utilized for the proposed bays under extension.	Confirmed, but extension work, wherever, required shall be in scope of Specification.
1.	400 KV GSS at Jodhpur		Please confirm that spare feeders in the existing auxiliary AC, DC & Lighting distribution boards shall be utilized for the proposed bays under extension.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
2.	General		We presume that the existing Battery & Battery Charger capacity is adequate for present scope of work.	Refer Pre-bid Clarification No. 1 issued vide this office letter No. 937 dated 16.06.10.
3.	General		Please confirm that existing facilities for earthing, illumination, main cable trench and lightning protection shall be utilized for the proposed bays under extension.	Confirmed, but extension work, wherever, required shall be in scope of Specification.

5. M/s. ECI Engineering & Construction Company Ltd., Plot No. 70' Anshu Colors' 3<sup>rd</sup> Floor, Road, No.1, Jubilee Hills, Hyderabad- 500 033. Fax No. :-040-23552980  
E-Mail:- [eci@eciecc.com](mailto:eci@eciecc.com)
6. M/s. Easun Products of India Pvt. Ltd., Temple Tower, 672,Anna saloi, Chennai 600 035. Fax No. 044-24346435 E-Mail:-[epil@easungroup.com](mailto:epil@easungroup.com)
7. M/s. SPML Infra Ltd., 4<sup>th</sup> Floor, Tower-ii, NBCC Plaza, Pushp Vihar, Sector-V, Saket, New Delhi- 110 017. Fax No.:-011-46861222 E-Mail :- [delhi@spml.co.in](mailto:delhi@spml.co.in),  
[info@spml.co.in](mailto:info@spml.co.in)
8. M/s Techno Electric And Engineering co. Ltd., P-46A, Radha Bazar Lane, Kolkatta-700 001. Fax No. :- 033-22254478 E-Mail :- [techno@cal.vsnl.net.in](mailto:techno@cal.vsnl.net.in)
9. M/s. ICSA India Limited, Plot# 12, Software Units Layout, Cyberbad, Hyderabad- 500 081. Fax No. :- 040-23114921 E-Mail :- [info@icsa-india.com](mailto:info@icsa-india.com)
10. M/s. A2Z Maintenance & Engineering Services Ltd.,0-116, First Floor,Shopping mall, DLF City, Phase-1, Gurgaon- 122 002. Fax No.:- 0124-2566582, 4380014 451767  
E-Mail :- [info@a2zemail.com](mailto:info@a2zemail.com)
11. M/s. UB Engineering Ltd., A-83,DDA Sheds, Okhla Indl. Area, Phase-II, New Delhi-110 020.Fax No.:- 011-40597713 E-Mail :- [delhioff@ubengg.in](mailto:delhioff@ubengg.in)
12. M/s. KEI Industries Ltd., 7, Kailash Path, Suraj Nagar-West, Civil Lines, Jaipur- 302 006. Fax No. +91-11-26811959, 26817225. E mail . [keiind@vsnl.com](mailto:keiind@vsnl.com)
13. M/s.Bharat Heavy Electricals Limited, Nehru Place, 1<sup>st</sup> Floor, NF/0/03, Tonk Road, Jaipur – 202 015. (E mail [bsaha@bhelindustry.com](mailto:bsaha@bhelindustry.com) ) Fax No.0141-2743314.
14. M/s.Vijay Electricals Ltd., 6-3-648/1&2, Off Raj Bhavan Road, Somajiguda, Hyderabad – 500 082, Andhra Pradesh, India. Fax No. +91 40 3061 7891. E Mail [projects@vijai.co.in](mailto:projects@vijai.co.in)
15. M/s.Tesla Transformers Limited, 30-B, Industrial Area, Govindpura, Bhopal – 462 023 (India). [projects@vijai.co.in](mailto:projects@vijai.co.in) Fax No. +91-755-2581865.
16. M/s.Bharat Bijlee Limited, Electric Mansion, 6<sup>th</sup> Floor, Appasaheb Marathe Marg, Prabhadevi, Mumbai – 400 025.
17. M/s.Simms Engineering Pvt. Ltd., 345, Bhaiya Para, Jaisalmer – 345 001.

  
**Superintending Engineer  
(400kV Design), RVPN, Jaipur.**



RAJASTHAN RAJYA VIDHYUT PRASARAN NIGAM LTD  
REGD. OFFICE: VIDYUT BHAWAN, JANPATH, JYOTI NAGAR, JAIPUR  
OFFICE OF THE SUPERINTENDING ENGINEER (400 KV DESIGN)  
Telephone No. 2740751; Fax No. 2740794;  
Email: - [se\\_400\\_kv\\_design@rvpn.co.in](mailto:se_400_kv_design@rvpn.co.in)

NO. RVPN/SE(400 KV DESIGN)/XEN (C&P)/TN-294/D. 1057 JAIPUR, DT: 23/6/2010

M/s.Larsen & Toubro Limited,  
Mount Poonamallee Road,  
Manapakkam, P.B.No.979,  
Chennai – 600 089.  
(Email : [mjs@lnt.com](mailto:mjs@lnt.com))

Sub:- Specification for Supply and ETC for Construction of 400 kV & 220 kV bays  
at 400 kV GSS Barmer, Jaisalmer & Jodhpur against TN-294.

Ref:- Your letter No. RVPN/EHV/TN-292 & RVPN/EHV/TN-294 dated 21.6.10.

Dear Sir(s),

With reference to your letter referred above, please find enclosed herewith the “Pre-Bid Clarification No.2”.

Please note that no further clarification / queries shall be entertained by this office.

This is without prejudice to various terms and conditions of the specification.

Encl: As above.

Thanking You,

Yours faithfully,

(M.L.Mathur)  
Superintending Engineer  
(400kV Design), RVPN, Jaipur.

Copy to :-

1. M/s.Areva T&D India Ltd., 106, 1<sup>st</sup> Floor, Sangam Tower, Church Road, Jaipur 302 001. (E mail [dheeraj.sharma@areva-td.com](mailto:dheeraj.sharma@areva-td.com)) Fax No: 0141-2387123.
2. M/s. ABB Ltd., C-116, Alakhnanda, 11<sup>th</sup> floor, Behind Vidhan Sabha, Janpath, Jaipur-302015. Fax No. :- 0141-274402.
3. M/s.Areva T&D India Ltd., 106, 1<sup>st</sup> Floor, Sangam Tower, Church Road, Jaipur 302 001. (E mail [dheeraj.sharma@areva-td.com](mailto:dheeraj.sharma@areva-td.com)) Fax No: 0141-2387123.
4. M/s. G.E.T Power Pvt. Ltd., 153, Developed Plots, Electrical & Electronics Industrial Estate, Perungudi, Chennai-600 096. Fax No. :- 044-45991000  
E-Mail :- [get@getpower.in](mailto:get@getpower.in)