



RAJASTHAN RAJYA VIDHYUT PRASARAN NIGAM LTD  
REGD. OFFICE: VIDYUT BHAWAN, JANPATH, JYOTI NAGAR, JAIPUR  
OFFICE OF THE SUPERINTENDING ENGINEER (400 kV DESIGN)  
Telephone No. 2740751; Fax No. 2740794;  
Email: - [se\\_400\\_kv\\_design@rvpn.co.in](mailto:se_400_kv_design@rvpn.co.in)

NO. RVPN/SE(400 kV DESIGN)/XEN (C&P)/TN-294/D. 1085JAIPUR, DT: 25/06/2010

M/s.Areva T&D India Ltd.,  
106, 1<sup>st</sup> Floor,  
Sangam Tower,  
Church Road,  
Jaipur 302 001.  
(E mail [dheeraj.sharma@areva-td.com](mailto:dheeraj.sharma@areva-td.com))

Fax No: 0141-2387123.

Sub:- Specification for Supply and ETC for Construction of 400 kV & 220 kV bays  
at 400 kV GSS Barmer, Jaisalmer & Jodhpur against TN-294.

Ref:- Your letter No. EI100053 & EI100054 dated 24.6.10.

Dear Sir(s),

With reference to your letter referred above, please find enclosed herewith the "Pre-Bid Clarification No.3".

Please note that no further clarification / queries shall be entertained by this office.

This is without prejudice to various terms and conditions of the specification.

Encl: As above.

Thanking You,

Yours faithfully,

(M.L.Mathur)  
Superintending Engineer  
(400kV Design), RVPN, Jaipur.

Copy to :-

1. M/s.Larsen & Toubro Limited, Mount Poonamallee Road, Manapakkam, P.B.No.979, Chennai – 600 089. (Email:mjs@Intecc.com)
2. M/s. ABB Ltd., C-116, Alakhnanda, IIIrd floor, Behind Vidhan Sabha, Janpath, Jaipur-302015. Fax No. : 0141-274402.
3. M/s. Jyoti Structures Ltd., Valecha Chambers, 6<sup>th</sup> Floor, New Link Road, Oshiwara, Andheri (West), Mumbai 400 053. Fax No. :- 022-40915014 / 15 Email: [contact@jstl.co.in](mailto:contact@jstl.co.in)

4. M/s. G.E.T Power Pvt. Ltd., 153, Developed Plots, Electrical & Electronics Industrial Estate, Perungudi, Chennai-600 096. Fax No. :- 044-45991000  
E-Mail : [get@getpower.in](mailto:get@getpower.in)
5. M/s. ECI Engineering & Construction Company Ltd., Plot No. 70' Anshu Colors' 3<sup>rd</sup> Floor, Road, No.1, Jublee Hills, Hyderabad- 500 033. Fax No. :-040-23552980  
E-Mail: [eci@eciecc.com](mailto:eci@eciecc.com)
6. M/s. Easun Products of India Pvt. Ltd., Temple Tower, 672, Anna saloi, Chennai 600 035. Fax No. 044-24346435 E-Mail: [epil@easungroup.com](mailto:epil@easungroup.com)
7. M/s. SPML Infra Ltd., 4<sup>th</sup> Floor, Tower-ii, NBCC Plaza, Pushp Vihar, Sector-V, Saket, New Delhi- 110 017. Fax No.:-011-46861222 E-Mail : [delhi@spml.co.in](mailto:delhi@spml.co.in),  
[info@spml.co.in](mailto:info@spml.co.in)
8. M/s Techno Electric And Engineering co. Ltd., P-46A, Radha Bazar Lane, Kolkatta-700 001. Fax No. :- 033-22254478 E-Mail :- [techno@cal.vsnl.net.in](mailto:techno@cal.vsnl.net.in)
9. M/s. ICSA India Limited, Plot# 12, Software Units Layout, Cyberbad, Hyderabad- 500 081. Fax No. :- 040-23114921 E-Mail : [info@icsa-india.com](mailto:info@icsa-india.com)
10. M/s. A2Z Maintenance & Engineering Services Ltd., 0-116, First Floor, Shopping mall, DLF City, Phase-1, Gurgaon- 122 002. Fax No.:- 0124-2566582, 4380014 451767  
E-Mail : [info@a2zemail.com](mailto:info@a2zemail.com)
11. M/s. UB Engineering Ltd., A-83, DDA Sheds, Okhla Indl. Area, Phase-II, New Delhi-110 020. Fax No.:- 011-40597713 E-Mail : [delhioff@ubengg.in](mailto:delhioff@ubengg.in)
12. M/s. KEI Industries Ltd., 7, Kailash Path, Suraj Nagar-West, Civil Lines, Jaipur- 302 006. Fax No. +91-11-26811959, 26817225. E mail [keiind@vsnl.com](mailto:keiind@vsnl.com)
13. M/s. Bharat Heavy Electricals Limited, Nehru Place, 1<sup>st</sup> Floor, NF/0/03, Tonk Road, Jaipur – 202 015. E mail [bsaha@bhelinindustry.com](mailto:bsaha@bhelinindustry.com) Fax No.0141-2743314.
14. M/s. Vijay Electricals Ltd., 6-3-648/1&2, Off Raj Bhavan Road, Somajiguda, Hyderabad–500 082, Fax No. +91 40 3061 7891. E Mail [projects@vijai.co.in](mailto:projects@vijai.co.in)
15. M/s. Tesla Transformers Limited, 30-B, Industrial Area, Govindpura, Bhopal–462023  
[projects@teslatransformers.com](mailto:projects@teslatransformers.com), [tesla@sancharnet.in](mailto:tesla@sancharnet.in), Fax No. +91-755-2581865.
16. M/s. Bharat Bijlee Limited, Electric Mansion, 6<sup>th</sup> Floor, Appasaheb Marathe Marg, Prabhadevi, Mumbai – 400 025.
17. M/s. Simms Engineering Pvt. Ltd., 345, Bhaiya Para, Jaisalmer – 345 001.

  
**Superintending Engineer**  
**(400kV Design), RVPN, Jaipur.**

## Pre Bid Clarification No. 3 (TN-294)

(Ref. Letter No.EI100053 & EI100054 dated 23.6.10 of M/s. Areva, Noida)

S. No.	Volume / Book No.	Clause	Queries	Clarifications
1.	BOQ & Part-3, Vol.II		Protection Relays indicated in BOQ and in Control & Relay Panel Technical Specification (400kVDMOL-II/Part-3(Section-1)/ Control & Relay Panel SHT-24,25,26,27,28) are not matching. Kindly clarify as to which one is to be followed.	Protection Relays are indicated in BOQ only under Mandatory Spares for C&R Panel. Whereas, in SHT-24,25,26,27,28 of Part-3, Vol.II, configuration of respective C&R panels are indicated.
2.	BOQ & Part-3, Vol.II		Bus bar Protection Requirement mentioned in BOQ is 1 No. whereas in Control and Relay Panel Technical Specification different quantity for 400KV and 220KV system. Kindly clarify if busbar peripheral unit is to be provided for only bays under present scope of quantity indicated in 400kVDMOL-II/Part-3(Section-1)/ Control & Relay Panel is to be followed.	C&R Panel Part-3, Vol.II is the General Technical Specification.  Please note that busbar PU is to be provided for only bays under present scope of Specification.